


# Leading the Industry in **Solar Microinverter Technology**



APsystems breaks new ground once again with the QS1, a cutting edge microinverter design accommodating up to 4 high-capacity PV modules up to 365W+ with independent MPPT. A single-phase, smart grid-compliant microinverter, the QS1 features Zigbee wireless communication over a mesh network with faster data speeds than PLC, and a wider MPPT voltage range results in a greater energy harvest for homeowners.

A true utility-interactive microinverter with Reactive Power Control (RPC) technology, the QS1 is inherently NEC 2014/2017 Rapid Shutdown compliant. The unit also builds on the successful APsystems line of multi-module microinverters, simplifying installation and reducing logistics costs.



## **APsystems QS1 Microinverter Datasheet**

#### **INPUT DATA (DC)**

MPPT Voltage Range	22V-48V		
Operation Voltage Range	16V-55V		
Maximum Input Voltage	60V		
Startup Voltage	20V		
Maximum Input Current	12AÐ4		
Maximum DC short circuit current	15AÐ4		
OUTPUT DATA (AC)	240V	208V	
Maximum Continuous Output Power	1,200W	1,100W	
Nominal Output Voltage/Range	240V/211V-264V	208V/183V-229V	
Nominal Output Current	5.00A	5.29A	
Nominal Output Frequency/Range	60Hz/59.3Hz-60.5Hz		
Power Factor	>0.99		
Total Harmonic Distortion	<3%		
EFFICIENCY			
Peak Efficiency	96.5%		
Nominal MPPT Efficiency	99.5%	99.5%	

#### **MECHANICAL DATA**

Night Power Consumption

Operating Ambient Temperature Range	-40°F to +149°F(-40°C to +65°C)
Storage Temperature Range	-40°F to +185°F(-40°C to +85°C)
Dimensions (W x H x D)	11.1" x 9.1" x 1.6"(281mm Đ 231mm Đ 41.3mm)
Weight	9.9lbs(4.5kg)
AC Trunk Cable Maximum Current	20A
Enclosure Rating	NEMA 6
Cooling	Natural Convection - No Fans

30mW

#### **FEATURES**

Communication	Wireless (Zigbee)
Transformer Design	High Frequency Transformers, Galvanically Isolated
Monitoring	Via EMA* Online Portal
Warranty	10 years standard, extendable to 25 years

### **CERTIFICATE & COMPLIANCE**

Safety and EMC Compliance
Certificate & Compliance
Grid Connection Compliance

Rapid Shutdown



\*\* Meets the standard requirements for Distributed Energy Resources (UL 1741) and identified with the CSA Listed Mark.

Specifications subject to change without notice - please ensure you are using the most recent update found at www.APsystems.com

600 Ericksen Ave NE, Suite 200, Seattle, WA 98110 | 844.666.7035 | APsystems.com

FCC Part15;ANSIC63.4;ICES-003 UL1741\*\*, CSAC22.2No.107.1-01 IEEE1547 Meets NEC 2014/2017 690.12

